

SEWER BUILDERS RETURN

I HEREBY CERTIFY that the within connection enters lot at a point 12' feet South of  
North line of said lot and was properly made by me on 5<sup>th</sup> day of Sept 1927  
 in conformity with the specifications of Sanitary Engineering Department; that the connection was made with the recorded Y  
 branch or connection for said lot without opening or in any way injuring the main sewer; that said connection was laid to a  
 true and proper grade, and constructed of sound and substantial sewer pipe, with the joints properly  
 cemented and tight and that the whole was left in clean and good condition.

Measurement used was 154 feet from M.H. 6 X 37 Depth of connection at point of tap 5'  
 Depth of connection at lot line 5' 4" Connection in house made to Toilet & Sink  
 Roofwater ~~is~~ will be conducted under my contract to

Donatella Contracting Co  
 Licensed Sewer Builder

Approved W. M. Hyman Inspector

McIlrose Ave

GILIO

Mahoning Ave.

114 ft

Raccoon Road

This plan should show street names and distances to manholes from Y or lateral being connected.

Permit No. 86

Overland Sewer District

SEWER CONNECTION

Lot No. G.A. 10

Subdivision Overland Imp

Street Raccoon Rd

Recorded in Sewer Book

Vol. 4, Pg. 157

154

657  
119  
771